



CEILING TRUSSWAY UTILITIES:
 CONTINUOUS POWER PLUG-IN ELECTRICAL BUS DUCTS:
 - TRUSSWAYS 3,4,7,9,12,13: 1000 AMP, 480 VOLT, 3 PHASE, 3 WIRE
 - TRUSSWAYS 16, 17: 1600 AMP, 480 VOLT, 3 PHASE, 3 WIRE
 - TRUSSWAYS 20, 21: 2000 AMP MINIMUM, 480 VOLT, 3 PHASE, 3 WIRE
 - TRUSSWAYS C.E.: 800 AMP MINIMUM 480 VOLT, 3 PHASE, 3 WIRE
 600 AMP MINIMUM, 120/208 VOLT, 3 PHASE, 4 WIRE
 - CATWALK F: 800 AMP MINIMUM, 408 VOLT, 3 PHASE, 3 WIRE
GAS, AIR, WATER:
 - TRUSSWAYS 2 THROUGH 22, C, D, E, CATWALK F
STEAM:
 - TRUSSWAYS 16, 17, 20, 21

EXHIBIT HALL COLUMN UTILITIES:
 HALLS B,C:
 ▷ TWO 20 AMP, 120 VOLT, 1 PHASE, 3 WIRE RECEPTACLES
 HALLS D,E,F:
 ▷ TWO 20 AMP, 120 VOLT, 1 PHASE, 3 WIRE RECEPTACLES ON EMERGENCY POWER TWO TELEPHONE OUTLETS
FIBER OPTIC:
 SINGLE AND MULTI-MODE CABLE BACKBONE WITH CONNECTIVITY FOR DATA, VIDEO, ETHERNET AND INTERNET AVAILABLE IN ALL SERVICEWAYS.
INTERNET:
 TEN-MEGABYTE ACCESS AVAILABLE IN ALL SERVICEWAYS.
AIR:
 CONTINUOUS IN ALL SERVICEWAYS 90-100PSI, 1 1/2" HEADER, 3/4" TAP
NATURAL GAS:
 CONTINUOUS IN ALL SERVICEWAYS-6" WATER COLUMN PRESSURE, 2" HEADER, 1" TAP.
STEAM:
 AVAILABLE IN ONE SERVICEWAY IN EACH OF HALLS D,E,H, AND I, 10,000-LB.-PER-HOUR AT 100-125 PSI, 3" HEADER, 1" TAP.

CEILING HEIGHTS:
 HALLS A-E & G-J:
 27'-UNDER SERVICEWAYS
 55'-TRUSS PEAKS
 65'-ROOF PEAKS
 HALL F:
 36' MINIMUM
 HALLS E-F:
 20' FINISHED CEILING FROM ENTRANCE TO COLUMN LINE (SEE FLOOR PLAN)

CEILING TRUSSWAY UTILITIES:
 CONTINUOUS POWER PLUG-IN ELECTRICAL BUS DUCTS:
 -TRUSSWAYS 3,4,7,9,12,13: 1000 AMP, 480 VOLT, 3 PHASE, 3 WIRE
 -TRUSSWAYS 16, 17: 1600 AMP, 480 VOLT, 3 PHASE, 3 WIRE
 -TRUSSWAYS 20, 21: 2000 AMP MINIMUM, 480 VOLT, 3 PHASE, 3 WIRE
 -TRUSSWAYS C.E.: 800 AMP MINIMUM 480 VOLT, 3 PHASE, 3 WIRE
 600 AMP MINIMUM, 120/208 VOLT, 3 PHASE, 4 WIRE
 -CATWALK F: 800 AMP MINIMUM, 408 VOLT, 3 PHASE, 3 WIRE
GAS, AIR, WATER:
 -TRUSSWAYS 2 THROUGH 22, C, D, E, CATWALK F
STEAM:
 -TRUSSWAYS 16, 17, 20, 21

COLUMNS:
 ● COLUMN 4" DIAMETER - EXHIBIT HALLS
 ● COLUMN 2" DIAMETER - LA LOUISIANE BALLROOM
 ● COLUMN 3" DIAMETER - LOBBY A THRU F
 ● COLUMN 17" DIAMETER - BRIDGE COLUMN

EXHIBIT HALL UTILITIES:
 □ FLOOR BOX:
 30FT. ON CENTER, ONE 100 AMP 120/208 VOLT, 3 PHASE, 5 WIRE RECEPTACLE FOUR 20 AMP, 120 VOLT, 1 PHASE, 3 WIRE RECEPTACLES TELEPHONE CONNECTION AND INTERCOMMUNICATION DRAIN, 3"
 □ FLOOR BOX:
 SAME AS ABOVE, WITH WATER
 □ FLOOR BOX (HALL F - J):
 COMMUNICATION/DRAIN 100AMP/208 OR 4 20AMP CIRCUIT
 □ FLOOR BOX (HALL G - J):
 COMMUNICATION/DRAIN 100AMP/208 WITH 12 20AMP CIRCUIT

INTERNET:
 TEN-MEGABYTE ACCESS AVAILABLE IN ALL SERVICEWAYS.
AIR:
 CONTINUOUS IN ALL SERVICEWAYS 90-100PSI, 1 1/2" HEADER, 3/4" TAP
NATURAL GAS:
 CONTINUOUS IN ALL SERVICEWAYS-6" WATER COLUMN PRESSURE, 2" HEADER, 1" TAP.
STEAM:
 AVAILABLE IN ONE SERVICEWAY IN EACH OF HALLS D,E,H, AND I, 10,000-LB.-PER-HOUR AT 100-125 PSI, 3" HEADER, 1" TAP.

CEILING TRUSSWAY UTILITIES:
 CONTINUOUS POWER PLUG-IN ELECTRICAL BUS DUCTS:
 -TRUSSWAYS 3,4,7,9,12,13: 1000 AMP, 480 VOLT, 3 PHASE, 3 WIRE
 -TRUSSWAYS 16, 17: 1600 AMP, 480 VOLT, 3 PHASE, 3 WIRE
 -TRUSSWAYS 20, 21: 2000 AMP MINIMUM, 480 VOLT, 3 PHASE, 3 WIRE
 -TRUSSWAYS C.E.: 800 AMP MINIMUM 480 VOLT, 3 PHASE, 3 WIRE
 600 AMP MINIMUM, 120/208 VOLT, 3 PHASE, 4 WIRE
 -CATWALK F: 800 AMP MINIMUM, 408 VOLT, 3 PHASE, 3 WIRE
GAS, AIR, WATER:
 -TRUSSWAYS 2 THROUGH 22, C, D, E, CATWALK F
STEAM:
 -TRUSSWAYS 16, 17, 20, 21

FIRE EQUIPMENT:
 F - FIRE PULLBOX
 FP - FIRE PUMP
 ET - EMERGENCY TELEPHONE
 FV - FIRE VALVE

CLEAN® 2019

World Educational Congress for Laundry and Drycleaning, LLC

June 20-23, 2019

New Orleans Morial Convention Center Halls B-F

Floor Plan as of July 10, 2018

The floorplan is constantly changing as more companies contract to exhibit and spaces are assigned. Please visit www.cleanshow.com for the most current floorplan.